

ADDENDUM NUMBER 2

July 27, 2009

to

CONTRACT DOCUMENTS

for

Sign Replacement

HCAA Project Number 5650 09

TAMPA EXECUTIVE AIRPORT

Tampa, Florida

THE FOLLOWING ITEMS ARE MADE AND HEREBY BECOME A PART OF THE CONTRACT DOCUMENTS DATED JUNE 2009 FOR SIGN REPLACEMENT AT TAMPA EXECUTIVE AIRPORT, TAMPA, FLORIDA, AS PREPARED BY RW ARMSTRONG, INC.

BIDDERS ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN PAGE 00300-4 OF THE BID FORMS.

QUESTIONS & ANSWERS

1. Referencing Addendum No. 1, 10437-3/2.3D, wall-mounted panel signs, it states the lettering film to be 3M Scotchlite (reflective film) however, referencing 10437-4/Sect. 2.7, wall-mounted panel signs, it indicates that the lettering is non-reflective, please clarify.

The lettering film is to be non-reflective. The black lettering shall be cut from Scotchcal ElectroCut Series 7725 film. Color 7725-12 black.

HCAA PLANNING AND DEVELOPMENT



Glenn S. Scheafmocker, RA

End of Addendum No. 2